





Powering Green Future

## Declaration of Conformity -Ireland

<b>Inverter Model</b>		<b>Grid-Tied Inverter:</b> BluE-G 3000S/BluE-G 3000D/BluE-G 4000D/BluE-G 5000D BluE-G 6000D KSG-120CL/KSG-150UM KSG-136UH KSG-200UH/KSG-250UH KSG-10K/KSG-12K/KSG-15K/KSG-17K/KSG-20K KSG-30K/KSG-50K/KSG-60K KSG-36K-HV/KSG-50K-HV/KSG-60K-HV <b>Hybrid Inverter</b> BluE-S 3680D/BluE-S 5000D KSE-3.6K-048S/KSE-5K-048S /KSE-5K-048	
<b>Manufacturer Reference number</b>		202082001	
<b>Micro-generator technology</b>		String inverter and Hybrid inverter	
<b>Manufacturer name</b>		Shenzhen Kstar New Energy Co.,Ltd	
<b>Addres</b>		No.7th Road,Guangming Hi-Tech Industrial Zone, Shenzhen,Guangdong 518107 P.R.China	
<b>Tel</b>	+86 755 2138 9008	<b>Fax</b>	+86 755 2138 9006
<b>E:mail</b>	sales@kstar.com	<b>Web site</b>	http:www.kstar.com
<b>Interface Protection Setting for Ireland</b>			
<b>Parameters</b>	<b>Max Clearance Time</b>	<b>Trip Setting</b>	
<b>Over Voltage</b>	0.5s	230V+10%	
<b>Under Voltage</b>	0.5s	230V+10%	
<b>Over Frequency</b>	0.5s	50.0Hz+1%	
<b>Under Frequency</b>	0.5s	50.0Hz-4%	
Manufacturer Type Test declaration.-I certify that all products supplied by the company with the above Type Tested reference number will be manufactured and tested to ensure that they perform as stated in this document, prior to shipment to site and that no site modifications are required to ensure that the product meets all the requirements of EN50549, IEC 62109 and VDE 01261-1.			
<b>Signed</b>	 Zhao Bin	<b>On behalf of</b>	 Hao Huang